

Approval No : A/P/HQ/MH/104/7216 (P539000)

Dated : 20/06/2022

To,

M/s. Remi Elektrotechnik Limited,
Survey No. Survey No. 65/1,,
Building A Naik Pada Waliv, Waliv, Vasai East,
Vasai,
Taluka: Vasai,
District: THANE,
State: Maharashtra,
PIN: 401208

Sub : Approval of 3 Phase Flame Proof Induction Motors under Petroleum Rules 2002- Regarding.

Sir(s),

Please refer to your letter No. **OIN1078461** dated **07/06/2022** on the subject.

The following Ex electrical equipment(s) manufactured by you according to **IS/IEC 60079-0 2017, IS/IEC 60079-1 : 2014**, standards and covered under **Electronics Regional Test Laboratory (East)** Test reports mentioned below is/are approved for use in **Zone 1** of Gas **IIB** hazardous areas coming under the the Petroleum Rules, 2002 administered by this Organization.

Sr. No	Description	Safety Protection	Equipment reference Number	Test Agency			Drawing no
				Name	Certificate No.	Certificate Date	
1	3 Phase FLP induction (IE2) Motor Frame - 63B	Ex db IIB T6 Gb	P539000/1	Electronics Regional Test Laboratory (East)	ERTL (E)/TES/R248/0011/10-21/NABL	24/01/2022	FL-63-53-243 Rev 0
2	3 Phase FLP Induction (IE2) Motor Frame - 71B	Ex db IIB T6 Gb	P539000/2	Electronics Regional Test Laboratory (East)	ERTL (E)/TES/R248/0012/10-21/NABL	24/01/2022	FLP-71-53-244 Rev 0
3	3 Phase FLP Induction (IE2) Motor Frame - 80B	Ex db IIB T6 Gb	P539000/3	Electronics Regional Test Laboratory (East)	ERTL (E)/TES/R248/0013/10-21/NABL	24/01/2022	FLP-80-53-245 Rev 0
4	3 Phase FLP Induction (IE2) Motor Frame - 90C	Ex db IIB T6 Gb	P539000/4	Electronics Regional Test Laboratory (East)	ERTL (E)/TES/R248/0014/10-21/NABL	24/01/2022	FLP-90-53-246 Rev 0
5	3 Phase FLP Induction (IE2) Motor Frame - 100C	Ex db IIB T6 Gb	P539000/5	Electronics Regional Test Laboratory (East)	ERTL (E)/TES/R248/0015/10-21/NABL	24/01/2022	FLP-100-53-247 Rev 0
6	3 Phase FLP Induction (IE2) Motor Frame - 112B	Ex db IIB T6 Gb	P539000/6	Electronics Regional Test Laboratory (East)	ERTL (E)/TES/R248/0016/10-21/NABL	24/01/2022	FLP-112-53-248 Rev 0
7	3 Phase FLP Induction (IE2) Motor Frame - 132B	Ex db IIB T6 Gb	P539000/7	Electronics Regional Test Laboratory (East)	ERTL (E)/TES/R248/0017/10-21/NABL	24/01/2022	FLP-132-53-249 Rev 0

This Approval is granted subject to observance of the following conditions:-

- 1) The design and construction of the equipment shall be strictly in accordance with description, condition and drawings as mentioned in the Test Reports referred to above.
- 2) The equipment shall be used only with approved type of accessories and associated apparatus.
- 3) Each equipment shall be marked either by raised lettering cast integrally or by plate attached permanently to the main structure to indicate conspicuously:-
 - (a) Name of the manufacturer
 - (b) Name and number by which the equipment is identified.
 - (c) Number & date of the test report of the Electronics Regional Test Laboratory (East) applicable to the equipment.
 - (d) Equipment reference number of this letter by which use of apparatus is approved.
 - (e) BIS approval number.
 - (f) Protection level.
- 4) A certificate to the effect that the equipment has been manufactured strictly in accordance with the drawing referred to in the Test report and is identical with the one tested and certified at Testing agency shall be furnished with each equipment.
- 5) The customer shall be supplied with a copy of this letter, an extract of the conditions and maintenance schedule, if any, recommended by Electronics Regional Test Laboratory (East) and copy of instructions booklet detailing operation & maintenance of the equipment so as to maintain its safe characteristics.
- 6) The IS/IEC 60079-17 and IS/IEC 60079-19 shall be followed for maintenance and repair of overhaul of the subject equipments.

Conditions of the Approval:-

The approval for above motors is subject to validity of BIS License No. CM/L-3776884.

This approval also covers the permissible variations as approved under the Electronics Regional Test Laboratory (East) test reports referred above. This approval is liable to be cancelled if any of the conditions of the approval is violated or not complied with. The approval may also be amended or withdrawn at any time, if considered necessary in the interest of safety.

The field performance report from actual users/your customers of the subject equipment may please be collected and furnished to this office for verification and record on annual basis.

The Approval is Valid upto **31/12/2026**

Yours faithfully,

(A.B. Tamgadge)
Controller of Explosives
For Chief Controller of Explosives
Nagpur

Copy to :
1. Jt. Chief Controller of Explosives, West Circle, MUMBAI

for Chief Controller of Explosives
Nagpur

(For more information regarding status, fees and other details please visit our website <http://peso.gov.in>)

This is System Generated document. Signature is not required.